# 2014 Summer Readiness Briefing for Southern California Chambers

Robert B. Weisenmiller

Chair, California Energy Commission

August 21, 2014












### U.S. Drought Monitor California



#### August 12, 2014

(Released Thursday, Aug. 14, 2014) Valid 8 a.m. EDT

Drought Conditions (Percent Area)

	None	D0-D4	D1-D4	D2-D4	D3-D4	D4
Current	0.00	100.00	100.00	99.80	81.92	58.41
Last Week 85/2014	0.00	100.00	100.00	99.80	81.92	58.41
3 Month's Ago 5/13/2014	0.00	100.00	100.00	100.00	76.68	24.77
Start of Calendar Year 12/31/2013	2.61	97.39	94.25	87.53	27.59	0.00
Start of Water Year 104/2013	2.63	97.37	95.95	84.12	11.36	0.00
One Year Ago 843/2013	0.00	100.00	98.23	93.86	11.36	0.00

#### Intensity:



The Drought Monitor focuses on broad-scale conditions. Local conditions may vary. See accompanying text summary for forecast statements.

#### Author:

Richard Tinker CPC/NOAA/NWS/NCEP









http://droughtmonitor.unl.edu/











### Fire Activity As of Monday, August 14, 2014

- CAL FIRE has responded to **2,118** wildfires across the state since January 1, burning **17,159** acres.
- This year's fire activity is well above the year-to-date average of 1,255 wildfires for 10,477 acres.
- Over 210 new wildfires were reported over the past week.
- While drought conditions have continued to lead to a significant increase in the number of wildfires, additional firefighters, fire engines and firefighting aircraft staffed earlier than normal have allowed CAL FIRE to contain these wildfires quickly in most cases.













### 20 of Largest Wildfires in CA



















### Protecting Power Infrastructure

- To assist in preventing a disruption of the California power grid, CAL FIRE notifies the California Independent System Operator (CA-ISO) when wildland fires are determined to be a threat to power transmission lines.
  - Incident Commanders identify threats from wildfire to minor and major power supply.
  - Notification of threat is made through chain-of-command to Sacramento Command Center.
  - Sacramento Command Center notifies CA-ISO and CAL FIRE Executive Staff.
  - Threat to power grid is considered when prioritizing resource allocation (e.g., aircraft).












# Recap of 2012 - 2013: The early retirement of SONGS created issues jeopardizing reliability.













### Specific near term actions (2013 - 2018)

VARs	MW	VARs & MW
Extend Huntington Beach synchronous condensers yearly Ongoing	Flex-Alert funding beyond 2014 To be determined	Maintain capacity @ Cabrillo II 2013 Complete
Install synchronous condensers (w/SDG&E) @ Talega, San Onofre Mesa, San Louis Rey	Permit construction of Sycamore-Penasquitos 230kv line 2015 Pending	Timely action on Pio Pico 2014 Complete
Modify San Onofre voltage criteria (w/SCE) 2014  Complete	Authorize acceleration of EE, DR, DG, and storage procurement in target areas	Authorize procurement to replace Encina 2014  Complete
Evaluate conversion of one San Onofre unit to a synchronous condenser (w/SCE) 2014 Complete	Evaluate transmission alternatives and incremental reinforcement in 2013-2014 transmission plan Complete	Timely decisions to license replacements for OTC capacity  Pending
CPUC CEC	ISO	Create contingency process; including OTC extension and new generator permitting











# For 2014 System-wide: ISO operating reserves are good, even considering drought impacts.

On-Peak Resources (MW)	ISO	Southern California	Northern California
Existing generation	53,612	26,178	27,434
High probability additions	338	261	77
Hydro derate (below NQC)	(1,370)	(281)	(1,089)
Outages (1-in-2 generation)	(5,030)		
Net Interchange (moderate)	9,000		
Total net supply (MW)	56,550		
DR & Interruptible programs	2,066		
Demand (1-in-2 summer temperature)	47,351		
Operating Reserve Margin	23.8%		











# In the 2014 extreme scenario: ISO Operating reserve margin is greater than 13%.

On-Peak Resources (MW)	ISO	Southern California	Northern California
Existing generation	53,612	26,178	27,434
High probability additions	338	261	77
High hydro derate (below NQC)	(1,669)	(342)	(1,328)
High outages (1-in-10 generation)	(6,478)		
Net interchange (Low)	8,500		
Total net supply (MW)	54,303		_
DR & Interruptible programs	2,066		
High demand (1-in-10 summer temperature)	49,601		
Operating Reserve Margin	13.6%		











## San Diego and the Los Angeles Basin resource forecast for 2014:

#### Los Angeles Basin

	2014		2014
Total generation	3,126	Total generation	11,547
Import capability	2,900	Import capability	10,771
Largest generator outage	-603	Largest generator outage	-498
Load (1:10)*	-5,306	Load (1:10)*	-20,812
Additional margin	= 117+	Additional margin	= 1,008+

<sup>\*</sup> Load from CEC 2013 IEPR, April 15, 2014 Update

<sup>+</sup> For 2013 San Diego = 150, LA Basin = 667











### **Emergency Notifications**

Stages of Electrical Emergencies

#### **Operating Reserves**













# Contingency Plan for Excessive Heat Emergencies

- Plan describes state operations and notifications to local government during heat related emergencies. The Plan is activated when temperatures spike for 2 or more consecutive days without adequate drop in nighttime temperatures to cool indoor and outdoor environments.
- National Weather Service Predictions:
  - Excessive Heat Outlook issued 3-7 days in advance of event
  - Excessive Heat Watch issued 36-48 hours in advance of event
  - Excessive Heat Warning issued 0-36 hours in advance and expected to last 2 or more days
- Plan Activation Phases:
  - Phase I Seasonal Readiness (May-August) Awareness campaign
  - Phase II Heat Alert NWS predicts Excessive Heat Warning or power outages predicted
  - Phase III Heat Emergencies Operational Area or local emergency proclamations, abnormal animal and human mortality rates, CAISO Stage 3 Electrical Emergency or extended power outages











### Ongoing summer concerns include:

- Extreme heat storms of extended duration stress both transmission and local systems without nighttime cooling
  - Summer of 2012 was relatively mild; demand was moderate
  - Summer of 2013 was also mild with demand less than 2012
- Heat storms covering the entire Western US may reduce available imports
- Unforeseen, significant outages may reduce resources
- High fire danger and potential impact to transmission
  - Maximizing coordination with CalFire









